



August 25, 2023

File: 21020-50/WW/OP/Aylesbury

Village of Aylesbury  
Box 151  
AYLESBURY SK S0G 0B0

Attention: Waterworks Owner/Operator

**RE: Rescinding - Precautionary Drinking Water Advisory – Village of Aylesbury**

The Water Security Agency, in consultation with the Saskatchewan Health Authority, are advising that the **"Precautionary Drinking Water Advisory"**(PDWA) issued by the Water Security Agency for the Village of Aylesbury's potable water system be rescinded as of Friday August 25, 2023.

The rescinding of the PDWA was based upon information provided by your community, which included:

- Water treatment plant is producing water that meets or exceeds the permit to operate;
- Chlorine residuals throughout the WTP and distribution system are within regulatory requirements; and
- Bacteriological sampling is within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Village of Aylesbury in addressing the advisory.

Sincerely,

A handwritten signature in blue ink, appearing to read "D. Hoehn", is positioned above the typed name.

Derrick Hoehn, A.Sc.T.  
Supervisor, Environment Officer  
Water Security Agency

cc: Derrick Hoehn – Water Security Agency  
Saskatchewan Health Authority - Yorkton